



**South Jersey  
Water Test, LLC**

4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwatertest.com  
NJ DEP Certified Lab #08006

## Alloway Township School

43 Cedar Street  
Alloway, NJ 08001


### Results of Lead Analysis

Date & Time Sampled: 06/10/2017 14:00 - 15:31

Date & Time Analyzed: 06/21/2017 14:33 - 20:23

Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
ALL-KC-KIT3	<2.00	15.5
ALL-KC-KIT4	<2.00	15.5
ALL-IM-KIT	<2.00	15.5
ALL-KC-KIT2	<2.00	15.5
ALL-KC-KIT1	<2.00	15.5
ALL-DW-215	<2.00	15.5
ALL-DW-214	<2.00	15.5
ALL-DW-HALL1	<2.00	15.5
ALL-DW-210	<2.00	15.5
ALL-WC-HALL6	<2.00	15.5
ALL-WC-HALL4	<2.00	15.5
ALL-WC-HALL5	<2.00	15.5
ALL-DW-HALL2	<2.00	15.5
ALL-WC-HALL3	<2.00	15.5
ALL-NS-NUR	<2.00	15.5
ALL-DW-HALL4	<2.00	15.5
ALL-DW-HALL3	<2.00	15.5
ALL-WC-HALL2	<2.00	15.5
ALL-TW-FACUL	<2.00	15.5

Units - ug/L = ppb



**South Jersey  
Water Test, LLC**  
4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwatertest.com  
NJ DEP Certified Lab #08006

## Alloway Township School

43 Cedar Street  
Alloway, NJ 08001

### Results of Lead Analysis

Date & Time Sampled: 06/10/2017 14:00 - 15:31

Date & Time Analyzed: 06/21/2017 14:33 - 20:23


Sample Location	Sample Result	Action Level
ALL-SO-LIBOFF	11.3	15.5
ALL-DW-107	<2.00	15.5
ALL-SO-MNOFWK	5.41	15.5
ALL-WC-HALL1	<2.00	15.5
ALL-DW-106	<2.00	15.5
ALL-DW-101	2.39	15.5
ALL-DW-102	<2.00	15.5
ALL-DW-105	<2.00	15.5
ALL-DW-103	5.67	15.5
ALL-DW-104	2.40	15.5
ALL-WC-FAC	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.

  
Mark J. Riether, Laboratory Director

  
Date 7/5/17